



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

June 5, 2015

KUSEL EQUIPMENT CO
CINDY SCHADE/JAMES SZOLLAR
820 WEST ST
PO BOX 87
WATERTOWN WI 53094

Re: Description: FITTINGS STAINLESS STEEL
Manufacturer: KUSEL EQUIPMENT CO
Product Name: STAINLESS STEEL DRAINAGE FITTINGS (trans id 2547105)
Model Number(s): FLOOR DRAINS; 2" SCH. 40 (KEM 50 MEDIUM DUTY), 3" SCH. 40 (KEM 75 STANDARD OR MEDIUM DUTY), 4" SCH. 40 (KEM 100 STANDARD, MEDIUM DUTY, KEM100SP, KE LOW PROFILE, KE SIDE OUTLET OR KE100 CONE BODY), 4" SCH. 10 (KE400), 6" SCH. 10 (KE150) AND 8" SCH. 10 (KE150) SIZES WITH OR WITHOUT REMOVEABLE PERFORATED OR SOLID TYPE SEDIMENT BASKET; CLEANOUTS: KEC250 SCH. 40 IN 4" OR 6" SIZES; SCH. 40 P-TRAPS (KE200): 2", 3", 4", 6" AND 8" SIZES. 4" SIS FLOOR DRAIN ED-DRAIN 4" SCH. 40 OUTLET AND PERFORATED BASKET. ALL FITTINGS CONFORM TO ASME STANDARD A112.6.3.
Product File No: 20150130

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (2), 384.30 (3) AND 384.30 (5) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2020.

This approval supersedes the approval issued on April 17, 2013 under product file number 20130079.

This alternate approval is required because the standard these fittings conform to, ASTM A270, does not appear in s. SPS 384.30 Wis. Adm. Code.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail